

May, 20, 2016

Chris Claussen
Sudbury Station LLC
2134 Sevilla Way
Naples FL 34109

Re: Village at Sudbury Station Water connection requirement

Sudbury Water District System Rules and Regulations requires that new large water users (greater than 2,500 gallons per day) document water-impact to our system; the Villages project is proposing 250 living units of various bedroom sizes (1-3). I estimate that daily water use for a complex of this size may be as much as 50,000 gallons per day or more. You can view the District's Rules and Regulations at www.sudburywater.com.

Prior to water service approval the applicant is required to submit a Water Impact Report to Sudbury Water District including the following data:

- Estimated impact of the project on the District's water demand;
- Impact of the project to the District's existing supply system including; effects on water flow, speed and direction through existing water mains proximate to the new service line and include maintenance of adequate fire flow;
- Impact of the project with regard to the District's Water Management Act Withdrawal Permit compliance;
- Conditions and water conservation measures that will mitigate the effect of the project's impact.

Questions or concerns regarding this matter may be addressed by contacting me at your earliest convenience at (978) 443-6602.

Sincerely,



Rebecca McEnroe, PE
Superintendent

cc: Jody Kablack, Planning Director