
Subject: Peter's Way at Concord Road--traffic peer reviewer suggestions

From: Jeffrey S. Dirk, P.E.,PTOE [<mailto:jdirk@rdva.com>]

Sent: Friday, July 8, 2016 9:59 AM

To: Garber, Glenn <GarberG@sudbury.ma.us>

Cc: Miles, William <MilesW@sudbury.ma.us>; Nix, Scott <NixS@sudbury.ma.us>

Subject: RE: Peter's Way at Concord Road

Glenn:

If the raised island is to be removed or modified, I would suggest the following alternatives be considered:

- 1. Retain a standard 6-foot long raised island at the center of the driveway and use scored concrete to define the channelized area (an emergency vehicle would be able to drive over the scored concrete); or***
- 2. Eliminate the island and use either scored concrete or pavement markings to channelize exiting vehicles.***

If you should have any additional questions, please feel free to contact me.

Jeffrey S. Dirk, P.E., PTOE, FITE
Principal

Vanasse & Associates, Inc.

35 New England Business Center Drive

Suite 140

Andover, MA 01810-1066

Office: 978-474-8800 x830 || Mobile: 508-414-7924 || Fax: 978-688-6508

Email: jdirk@rdva.com

Web: www.rdva.com